

**Oshkosh Fire Department  
EAA 2009 Cook Tent Requirements**

- BOOTH
- NUMBER
- The tents must be fire retardant. (N.F.P.A. 701)
- There shall be No Smoking and signs posted.

**Fire extinguisher**

- A 2-½ pound Dry Chemical (2A) fire extinguisher is required.
- A “K” fire extinguisher is needed for all grease or oil cooking.
- Do not block fire extinguishers, exit ways, or exit doors; do not cover exit signs.
- The cook tent shall not be located within 20 feet of buildings, other tents, or parked cars.
- No public access into the cook tent unless approved by the Oshkosh Fire Department.
- Sawdust or wood chips inside tents shall be kept damp.

**Heating and cooking**

- Heating equipment shall be designed to vent to the outside air.
- Cooking and heating equipment shall not be located within 10 feet of exits or combustible materials.
- Electrical cooking and heating equipment shall comply with the ICC *Electrical Code*.
- Portable LP tanks shall not be used for securing tents.
- Portable LP-gas containers less than 500 gallons shall have a minimum separation of at least 10 feet.